PROJECT NAME:	
BUILDING PERMIT #:	APN#:
SITE ADDRESS:	
home. To assist us with Fire required wording from the Na permanent with 1/2 inch mini	you are installing an emergency generator for your Department Emergency Operations, please review the ational Electrical Code Sec. 70-90b. The sign must be mum letters contrasting with the background color. Price this project, this sign (or approved alternate) must be e of the following locations:
	Main Exterior Electrical Shut Off
	Meter
	As follows:

THIS SERVICE CONNECTION IS FED BY A STANDBY EMERGENCY GENERATOR LOCATED AT (FILL IN LOCATION OF GENERATOR HERE)

Please complete and attach to plans.(Plans shall be submitted electronically or Paper 17x11 inches)

If not all of this information seems appropriate for the type of project being submitted, consult the Prevention and Planning Office to seek guidance on how much of this information should be on your specific plans.

This guideline is prepared to assist individuals in providing complete information for small and large project plan reviews.

If generator form is not completed in full, the plans will be returned and will delay the process for your project.

Protection and Planning Pebble Beach, Cypress, Carmel Highlands Fire Protection Districts and CAL FIRE Office- (831) 375-9644